

AD-A067 694


NAVAL POSTGRADUATE SCHOOL MONTEREY CALIF  
DEVELOPMENT OF A DEVICE FOR THE INCORPORATION OF MULTIPLE SCANI--ETC(U)  
MAR 79 R N GEOPFARTH  
NPS67-79-002

F/G 9/2

UNCLASSIFIED


NL

1 OF 2  
AD  
A067694



END  
DATE  
6/79  
DDC

CONT



MICROCOPY RESOLUTION TEST CHART  
NATIONAL BUREAU OF STANDARDS-1963-A

14 NPS67-79-002

LEVEL II

2

NW

NAVAL POSTGRADUATE SCHOOL  
Monterey, California

ADA067694



DDC  
RECEIVED  
APR 23 1979  
D

DDC FILE COPY

9 Master's THESIS

6 Development of a Device for the  
Incorporation of Multiple Scanivalves  
into a Computer-Controlled Data System.

by

10 Robert Neldon/Geopfarth

11 March 1979

12 83 p.

Thesis Advisor:

R.P. Shreeve

Approved for public release; distribution unlimited

Prepared for:  
Naval Air Systems Command  
Washington, DC

251 450  
79 04 19

UNCLASSIFIED

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

REPORT DOCUMENTATION PAGE		READ INSTRUCTIONS BEFORE COMPLETING FORM
1. REPORT NUMBER NPS67-79-002	2. GOVT ACCESSION NO.	3. RECIPIENT'S CATALOG NUMBER
4. TITLE (and Subtitle) Development of a Device for the Incorporation of Multiple Scanivalves into a Computer-Controlled Data System		5. TYPE OF REPORT & PERIOD COVERED Master's Thesis: Mar 79
		6. PERFORMING ORG. REPORT NUMBER
7. AUTHOR(s) Robert Neldon Geopfarth		8. CONTRACT OR GRANT NUMBER(s)
9. PERFORMING ORGANIZATION NAME AND ADDRESS Naval Postgraduate School Monterey CA 93940		10. PROGRAM ELEMENT, PROJECT, TASK AREA & WORK UNIT NUMBERS
11. CONTROLLING OFFICE NAME AND ADDRESS Naval Postgraduate School Monterey CA 93940		12. REPORT DATE March 1979
14. MONITORING AGENCY NAME & ADDRESS (if different from Controlling Office) Naval Postgraduate School Monterey CA 93940		13. NUMBER OF PAGES
		15. SECURITY CLASS. (of this report) Unclassified
		15a. DECLASSIFICATION/DOWNGRADING SCHEDULE
16. DISTRIBUTION STATEMENT (of this Report) Approved for public release; distribution unlimited		
17. DISTRIBUTION STATEMENT (of the abstract entered in Block 20, if different from Report)		
18. SUPPLEMENTARY NOTES		
19. KEY WORDS (Continue on reverse side if necessary and identify by block number) Scanivalve-computer interface; pneumatic scanner; data acquisition system.		
20. ABSTRACT (Continue on reverse side if necessary and identify by block number) A controller (designated HG-78K) was built to permit manual and computer-directed acquisition of pneumatic data from multiple Scanivalves. The controller incorporated a low cost digital electronic circuit which was designed as a peripheral device on the Hewlett-Packard Interface Bus (HP-IB) to enable computer interrogation of port addresses of multiple Scanivalves. Computer programs were written in BASIC and FORTRAN languages		

DD FORM 1473  
1 JAN 73  
(Page 1)

EDITION OF 1 NOV 66 IS OBSOLETE  
S/N 0102-014-6601

UNCLASSIFIED

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

179 04 19 004



**UNCLASSIFIED**

~~SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)~~

and operation of the system was verified using HP-9830A  
and HP-21MX computers.

DD Form 1473  
1 Jan 73  
S/N 0102-014-6601

**UNCLASSIFIED**

2 ~~SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)~~

Approved for public release; distribution unlimited

Development of a Device for the Incorporation of Multiple  
Scanivalves into a Computer-Controlled Data System

by

Robert Neldon Geopfarth  
Lieutenant, United States Navy  
B.S., University of Kansas, 1972

Submitted in partial fulfillment of the  
requirements for the degree of

MASTER OF SCIENCE IN AERONAUTICAL ENGINEERING

from the

NAVAL POSTGRADUATE SCHOOL  
March 1979

Author

Robert N. Geopfarth

Approved by:

Raymond P. Shreene

Thesis Advisor

Max F. Plater

Chairman, Department of Aeronautics

William M. Tolles

Dean of Science and Engineering

ADDITIONAL TO	
DTIC	Write Section <input checked="" type="checkbox"/>
DDC	Diff Section <input type="checkbox"/>
UNCLASSIFIED	<input type="checkbox"/>
JUSTIFICATION	
BY	
DISTRIBUTION/AVAILABILITY CODES	
Dist.	AVAIL. and/or SPECIAL
A	

D D C  
RECEIVED  
APR 23 1979  
D

# ABSTRACT

A controller (designated HG-78K) was built to permit manual and computer-directed acquisition of pneumatic data from multiple Scanivalves. The controller incorporated a low cost digital electronic circuit which was designed as a peripheral device on the Hewlett-Packard Interface Bus (HP-IB) to enable computer interrogation of port addresses of multiple Scanivalves. Computer programs were written in BASIC and FORTRAN languages and operation of the system was verified using HP-9830A and HP-21MX computers.

## TABLE OF CONTENTS

I.	INTRODUCTION .....	11
II.	HG-78K SCANIVALVE CONTROLLER .....	14
	A. DESIGN REQUIREMENTS .....	14
	B. MANUAL OPERATION .....	14
	C. COMPUTER OPERATION .....	15
	D. HG-78K SCANIVALVE CONTROLLER LAYOUT .....	16
III.	S/V MUX PCB DESCRIPTION .....	17
	A. GENERAL FEATURES .....	17
	B. HP-IB CONSIDERATIONS .....	18
	C. CIRCUIT DESCRIPTION .....	20
	1. DATA I/O Section .....	21
	2. DEVICE ADDRESS Section .....	22
	3. DATA STORAGE Section .....	23
	4. MULTIPLEXER Section .....	24
	5. HANDSHAKE Section .....	24
	6. CLOCK and CLEAR Sections .....	26
	7. HP-IB DISPLAY .....	27
	D. HARDWARE DESCRIPTION .....	28
	E. "DAV" DRIVER LINE DELAY ADJUSTMENT .....	28
IV.	PROGRAMMING INSTRUCTIONS .....	30
	A. I/O SPECIFICATIONS .....	30
	B. SAMPLE PROGRAM CODE .....	30
V.	CONCLUSIONS AND RECOMMENDATIONS .....	32



APPENDIX A: DATA ACQUISITION PROGRAM EXAMPLES .....	55
A.1 -- HP-9830A BASIC Program .....	57
A.2 -- HP-21MX FORTRAN Program .....	57
APPENDIX B: HG-78K HARDWARE .....	64
B.1 -- HG-78K Input/Output Wiring .....	64
B.2 -- S/V Address Decoder/Driver PCB .....	64
APPENDIX C: S/V MUX PCB HARDWARE .....	74
LIST OF REFERENCES .....	79
INITIAL DISTRIBUTION LIST .....	80



## LIST OF TABLES

I.	Logical Equivalences .....	33
II.	Logic Circuit Conventions .....	34
A1.	HP-IB Device Codes .....	55
A2.	Scanner #1 Channel Assignments .....	56
A3.	HP-9830A Program Listing .....	58
A4.	HP-21MX Program Listing .....	60
B1.	24-PIN HP-IB Connector .....	66
B2.	19-PIN Transducer Connector .....	67
B3.	14-PIN Frequency Connector .....	68
B4.	19-PIN Scanivalve Input Connectors .....	69
B5.	6-PIN Scanivalve Advance Connector .....	70
B6.	6-PIN Scanivalve Home Connector .....	70
B7.	S/V Address Decoder/Display Edge Connections ....	73
C1.	S/V MUX PCB Component Listing .....	75
C2.	S/V MUX PCB Test Point Summary .....	76
C3.	S/V MUX PCB Left Edge Connections .....	77
C4.	S/V MUX PCB Right Edge Connections .....	78

## LIST OF FIGURES

1. Scanivalve Functions .....	35
2. HG-78K Scanivalve Controller .....	36
3. Scanivalve Computer System Installation.....	37
4. HG-78K Functional Block Diagram.....	38
5. HP-IB Lines .....	39
6. S/V MUX PCB Block Diagram .....	40
7. Bi-Directional Bus Connections .....	41
8. Data I/O Section .....	42
9. Device Address Section .....	43
10. HP-IB Address Word Format .....	44
11. Data Storage Section .....	45
12. Multiplexer Section .....	46
13. Handshake Section .....	47
14. Listener Timing Diagram .....	48
15. Talker Timing Diagram .....	49
16. DAV Time Delay Sequence.....	50
17. Clock and Clear Sections.....	51
18. HP-IB Display.....	52
19. S/V MUX PCB.....	53
20. Modified Multiplexer Section.....	54
B1. HG-78K Back Panel Layout.....	65
B2. Transducer Signal Conditioning.....	71
B3. Scanivalve Address Decoder/Display Circuit.....	72

## TABLE OF ABBREVIATIONS

ADR <sub>L</sub>	Addressed to Listen
ADR <sub>T</sub>	Addressed to Talk
BCD	Binary Coded Decimal
CR	Carriage Return
DVM	Digital Voltmeter
DVR	Driver
EOI	End-of-Information
IC	Integrated Circuit
I/O	Input/Output
LED	Light Emitting Diode
LF	Line Feed
MUX	Multiplexer
NC	No Connection
PCB	Printed Circuit Board
RCVR	Receiver
S/V	Scanivalve
TX	Transducer

## ACKNOWLEDGEMENT

Significant technical achievements occur as a result of teamwork. It is richly rewarding to have been a member of the team who produced the HG-78K Scanivalve Controller. The alphanumeric designation of this device represents the pride we share in its development.

Mr. J.E. Hammer was principally responsible for the major design concept formulation and device requirements. His extensive instrumentation experience and knowledge of data acquisition requirements produced concise physical design specifications.

Mr. J.C. King, a man of infinite resource, was principally responsible for the hardware fabrication of both the HG-78K and the intricate S/V MUX PCB. His experience and competence in electronics, plus his ability to acquire impossible-to-find parts, were responsible for the rapid transition from schematic design to physical reality.

Associate Professor R.P. Shreeve guided the team's effort. His attentive support and his faith and trust in his team created a professional and fertile environment in which to complete this work.



## I. INTRODUCTION

In tests of compressors and turbines, simultaneous measurements of many steady-state pressures are required. In past years, Scanivalves<sup>1</sup> have been used for this purpose at the Turbopropulsion Laboratory at the Naval Postgraduate School. Up to four Scanivalves were incorporated into a data logging system which output data on paper tape [1]. In order to replace this system with on-line data acquisition to the Laboratory's new computer system, a Scanivalve control device compatible with the computer system was required. This report documents the logic and hardware design of the HG-78K Scanivalve Controller which was designed and built to answer this requirement. The new device permits acquisition of steady-state data from multiple Scanivalves under manual or computer control. The design incorporates low-cost digital electronic circuits and the unit itself functions as a computer peripheral device on the Hewlett-Packard Interface Bus (HP-IB)<sup>2</sup>. The development was carried out primarily to satisfy the data acquisition requirements of a transonic

---

<sup>1</sup>"Scanivalve" is the registered trademark for a mechanical pneumatic selector switch manufactured by Scanivalve Corporation, P.O. Box 20005, San Diego, California 92120.


<sup>2</sup>The HP-IB is the Hewlett-Packard implementation of IEEE Standard 488-1975, "Digital Interface for Programmable Instrumentation".



compressor research program sponsored by Naval Air Systems Command, Code 310A.

The Scanivalve (S/V) is a device having multiple pneumatic input ports and a single pressure-measuring transducer. A mechanical rotor, driven by an electric motor, pneumatically connects one input port at a time to the transducer. Rotor position is controlled electronically. The transducer output is a voltage which, after proper conditioning, can be measured using a precision voltmeter and, through calibration, interpreted as pressure.

Operation of a Scanivalve involves three essential tasks: Address interrogation, position control and transducer measurement. Address interrogation is the process by which the Scanivalve port address is identified. Position control involves the process by which the Scanivalve is positioned to a specified input port. Transducer measurement involves the process by which the electrical output of the pressure transducer is transformed and sampled. These three tasks are completely independent, yet are involved each time Scanivalve data is taken. In this report the concept of these essential tasks is referred to as the "Task Triad":



In the following section the operation and description is given for the HG-78K Scanivalve Controller which was designed to perform the above tasks. The device is a single control station which features digital port address display, manual S/V control functions, signal conditioning, transducer outputs and computer address interrogation of each of the five laboratory Scanivalves. In Section III, a detailed description is given of the Scanivalve multiplexer printed circuit board (S/V MUX PCB). This digital electronic device was designed to perform the address interrogation task for multiple Scanivalves under computer control. Section IV contains programming instructions necessary to accomplish data transfer between the computer and the S/V MUX PCB. Conclusions and a recommended design improvement for the S/V MUX PCB are given in Section V. Sample computer programs which demonstrate the BASIC and FORTRAN code necessary to obtain steady-state data using the HP-21MX and the HP-9830A computers are given in Appendix A. Appendices B and C contain complete hardware documentation of the HG-78K Scanivalve Controller and the S/V MUX PCB, respectively.

## II. HG-78K SCANIVALVE CONTROLLER

### A. DESIGN REQUIREMENTS

The pressure transducer in a Scanivalve must be calibrated and checked at intervals. The calibration procedure involves applying a known pressure to an input port, selecting that port, and adjusting the resistance in the transducer bridge circuit to obtain the proper span and balance voltages. This procedure requires position control of the Scanivalve as well as electrical access to the transducer bridge circuit. The five Scanivalves in the Turbopropulsion Laboratory were at different locations. The first requirement was to provide a single location at which each of the five Scanivalves could be manually controlled and calibrated. Real-time display of the port address of each Scanivalve at the same location was required to complete the task triad.

The acquisition of data using the Scanivalves was to be programmed on the computer. Therefore, the second design requirement was to provide computer control of the task triad. The final requirement was that manual and computer-directed tasks be simultaneously operable. These requirements were met in the design of the HG-78K Scanivalve Controller.

### B. MANUAL OPERATION

The electrical arrangement of a Scanivalve is shown in Figure 1. The elements associated with the task triad can be identified

in this figure. Attention is directed to the binary coded decimal (BCD) form of the port address. Four lines (0-3) carry the binary code for the least significant decimal digit while the other three lines (4-6) carry the binary code for the most significant decimal digit. In the HG-78K, these address lines were connected to a decoder/display circuit board (Appendix B) to provide continuous digital display of the selected port on the front panel. A view of the front panel is shown in Figure 2.

Manual position control of the Scanivalve was enabled by connecting panel-mounted push-button switches in series with the control lines. Transducer bridge circuit junctions were wired to front panel receptacles, and the bridge span and balance potentiometer adjustment knobs were also mounted on the front panel.

### C. COMPUTER OPERATION

The Scanivalve installation in relation to the laboratory's computer equipment is shown in Figure 3. The interface bus (HP-IB) is controlled by either the HP-21MX or the HP-9830A computer. The other three devices shown connected to the bus in Figure 3 execute the task triad under the direction of either bus controller as follows:

- \*Address interrogation of a selected Scanivalve is performed by the S/V MUX PCB.

- \*Position control is obtained by closing predetermined relays (via a software command) in the HP-3495A Scanner, which



in turn connects the 24-Vdc S/V control voltage to the selected Scanivalve advance or home control line.

Transducer measurement of the pressure on the selected Scanivalve port is made by the HP-3455A DVM when a relay in the Scanner is commanded (in software) to connect the selected transducer output.

Representative programming code to execute the task triad is listed and described in Appendix A. Codes used to address the devices connected on the HP-IB are given in Table A1.

#### D. HG-78K SCANIVALVE CONTROLLER LAYOUT

A functional block diagram of the HG-78K is shown in Figure 4. The non-interference of manual and computer operations can be understood with reference to this figure. Address lines are connected in parallel. The S/V decoder/display PCB continuously displays the port addresses while the address data is simultaneously available to the computer by the S/V MUX PCB without interference. Manual control line switches and Scanner control relays are connected in parallel so that a position control function will occur whenever either electrical path is completed. Transducer output lines are connected in parallel to both the front panel test points and to the Scanner relays.

A description of the hardware and wiring plans for the HG-78K Scanivalve Controller is given in Appendix B.



### III. S/V MUX PCB DESCRIPTION

#### A. GENERAL FEATURES

The S/V MUX PCB was designed to satisfy the following requirements:

1. Perform the Scanivalve port address interrogation task under control of either laboratory computer.
2. Perform random port address interrogation of multiple Scanivalves.
3. Function independently from the manual features of the HG-78K Scanivalve Controller.

To satisfy the first requirement, the S/V MUX PCB was designed as a peripheral device on the HP-IB, as shown in Figure 3. This approach offered significant advantages. First, logic circuits could be designed to respond to the established protocol of a single device, the HP-IB, rather than individual laboratory computers. Second, HP-IB compatible computers could be added or changed in the future without affecting circuit performance or causing hardware alterations.

The second design requirement was accomplished by electronically selecting the Scanivalve address information in the following way. Referring to Figures 1 and 3, port address data (7-bits) from the five Scanivalves are input to the S/V MUX PCB. Corresponding bits are connected to input ports of seven multiplexer IC's. A binary number, representing the Scanivalve to

be selected, is sent from the computer to the S/V MUX PCB where it is stored and routed to the address inputs of the seven multiplexer IC's. Each multiplexer IC, representing one bit of the S/V port address, electronically selects the input line represented by the binary code latched on its address input. The state of the selected input lines are transferred to the bus line drivers for transmission to the computer. Computer software then decodes the S/V address.

The third design requirement was accomplished by simply connecting manual and computer-controlled functions into electrically parallel paths. A special high-current relay module was installed in the HP-3495A Scanner to provide ten relays for handling the Scanivalve control lines. Scanner relay/channel assignments are listed in Table A2. Control current can be routed to a Scanivalve by either pressing a button on the front panel or by issuing a computer command to close a parallel-connected Scanner relay. In a similar manner, transducer voltage lines were connected to both the front panel outlets and to HP-3495A Scanner relays which were connected to the HP-3455 DVM. Scanivalve address information was parallel-connected to both the Decoder/Display PCB and to the S/V MUX PCB and was continuously available to either device.

#### B. HP-IB CONSIDERATIONS

All devices connected to the HP-IB must conform to a rigidly-defined protocol. Reference 2 presents an excellent description

of the features, protocol and electrical characteristics of the bus. Presented here is a brief overview of the HP-IB environment.

The HP-IB is a serial-byte interface which permits bi-directional communication between multiple instruments. All instruments on the bus can be uniquely addressed and can function as one of the following:

bus CONTROLLER -- controls bus information flow

bus LISTENER -- receives information from the bus

bus TALKER -- sends information to the bus

Bus communication uses sixteen lines which have been organized into three functional types:

DATA lines (8)

TRANSFER lines (3)

CONTROL lines (5)

The bus lines used by the S/V MUX PCB are shown with their mnemonic definitions in Figure 5.

The S/V MUX PCB uses only two control lines; IFC and ATN. The IFC line is driven by the bus CONTROLLER to initialize the bus and clear any bus activity. The ATN line is driven by the bus CONTROLLER and places the bus in either the COMMAND mode or in the DATA mode. In the COMMAND mode, address information is transmitted on the data lines to establish those instruments that are to talk, listen or remain dormant. In the DATA mode, the instrument addressed to talk will communicate on the data lines with those instruments addressed to listen. Only one TALKER is permitted.

The three transfer lines (DAV, NRFD, NDAC) execute the transfer of each information byte on the data lines by an interlocked "handshake" technique. This allows asynchronous data transfer at the speed of the slowest instrument on the bus. The DAV line is driven by the TALKER and indicates the validity of information on the data lines. When DAV is driven true, information on the DATA lines is unconditionally valid. The NRFD and NDAC lines are driven by all LISTENERS to indicate if they are ready to accept data or if the data has been accepted. When NRFD is driven false, a LISTENER indicates that it is unconditionally ready to accept one information byte. When NDAC is driven false, a LISTENER indicates that the information byte has been unconditionally accepted, and that the information on the data lines is no longer needed.

#### C. CIRCUIT DESCRIPTION

The following sequence of events occurs each time the S/V MUX PCB supplies the computer with Scanivalve address information:

1. Bus placed in COMMAND mode.
2. S/V MUX PCB addressed to LISTEN.
3. Bus placed in DATA mode.
4. Data byte sent to S/V MUX PCB.
5. Bus placed in COMMAND mode.
6. S/V MUX PCB addressed to TALK.
7. Bus placed in DATA mode.
8. Computer reads one data byte.



The remainder of this section describes in detail the digital circuit designed to implement this transfer sequence in the HP-IB environment.

Boolean algebraic expressions were written for each circuit line to define the required logic. Implementation of these expressions in hardware often made use of the logical equivalences shown in Table I. The circuit conventions which identify component labeling and line states are given in Table II.

A functional block diagram of the S/V MUX PCB is shown in Figure 6. The following discussion describes each block in detail. Reference is made to detailed schematic diagrams in which components are identified by numbers that follow standard practice. Hardware components are identified in Appendix C.

#### 1. DATA I/O Section

Bi-directional data lines are used because the S/V MUX PCB functions at different times as both a LISTENER and a TALKER. The logical devices used to form bi-directional bus lines are shown in Figure 7. The receiver is a standard inverter while the driver is an open-collector NAND gate. Each individual bus line, whether used or not, must be terminated in the resistor divider network shown. Four of these bi-directional circuits are contained in a single bus transceiver IC (MC3441P).

The DATA I/O section schematic is shown in Figure 8. In this section the ATN control line and the seven data lines, DI01 through DI07, are connected from the HP-IB to bus transceivers U1 and U2. Data line DI08 is not used and is terminated



by the resistor divider network formed by R1 and R2. All received lines are inverted for use in other parts of the circuit. Driver input lines to U1 and U2 from the multiplexer section identify the selected Scanivalve port address. The DRIVE ENABLE line (from the HANDSHAKE section) enables the bus drivers in U1 and U2 to place data on the data lines.

## 2. DEVICE ADDRESS Section

The DEVICE ADDRESS section is shown in Figure 9. This section determines when the S/V MUX PCB has been addressed to talk or to listen. When the bus is in the COMMAND mode (ATN), the bus CONTROLLER places an address word on the data lines. The address word format is shown in Figure 10. If the received address word corresponds to the address physically set on the circuit board, the logic state of one address line ( $ADR_T$  or  $ADR_L$ ) will be defined "true". The state of this line will remain valid after the bus returns to the DATA mode ( $\overline{ATN}$ ), unless cleared by IFC.

A five bit comparator (U6) was used to implement the ADDRESS ENABLE line defined as:

$$\text{ADDRESS ENABLE} = (\text{DAV}) \cdot (B = A)$$

where A = bit pattern set by the address switch

B = bit pattern received on the data lines.

When DAV is true and the bit patterns match, the ADDRESS ENABLE line goes high to enable U27(a) and U27(b).

The  $ADR_T$  line is defined by the following expression:

$$ADR_T = (ATN \cdot \overline{B6} \cdot B7 \cdot \text{ADDRESS ENABLE}) + (\text{TALK HOLD})$$

where  $\text{TALK HOLD} = (ADR_T \cdot \overline{\text{UNTALK}})$

$$\text{UNTALK} = (ATN \cdot B1 \cdot B2 \cdot B3 \cdot B4 \cdot B5 \cdot \overline{B6} \cdot B7)$$

The  $ADR_T$  expression is implemented by U27(a), U30(c), U7(c), U26 and U30(d). The  $ADR_T$  output line is set when U7 receives a positive-edged clock pulse. The TALK HOLD logic allows the  $ADR_T$  line to remain valid after the bus returns to the DATA mode ( $\overline{ATN}$ ).  $ADR_T$  is cleared by making TALK HOLD false or by a CLEAR signal to U7.

A similar circuit was used to implement the  $ADR_L$  line which is defined as follows:

$$ADR_L = (ATN \cdot B6 \cdot \overline{B7} \cdot \text{ADDRESS ENABLE}) + (\text{LISTEN HOLD})$$

where  $\text{LISTEN HOLD} = (ADR_L \cdot \overline{\text{UNLISTEN}})$

$$\text{UNLISTEN} = (ATN \cdot B1 \cdot B2 \cdot B3 \cdot B4 \cdot B5 \cdot B6 \cdot \overline{B7})$$

The  $ADR_L$  expression is implemented by U27(b), U30(b), U7(b), U25 and U30(a). Implementation of the above expressions made use of the logical equivalence shown in Table I.

### 3. DATA STORAGE Section

The schematic diagram for the DATA STORAGE section is shown in Figure 11. Device U9 is a positive-edge-triggered flip-flop. Data appearing on its input is transferred to its output only when the clock line transitions from a low to a high state. Thus, data storage is completely controlled by the DATA STORE line connected to the clock input gate. This line is defined as follows:

$$(\text{DATA STORE}) = (\overline{ATN} \cdot ADR_L \cdot \text{DAV})$$

When addressed to listen while the HP-IB is in the DATA mode, the three least significant bits on the data lines will be stored whenever the TALKER sets DAV true. The three bits, A1, A2 and A3 are used to select Scanivalve address data.

#### 4. MULTIPLEXER Section

The MULTIPLEXER circuit is shown in Figure 12. Address lines A1, A2 and A3 are connected to the data select pins of multiplexers U10-U16. The bit pattern on these lines determines which one of eight multiplexer input lines is selected. In this circuit only inputs one through five are connected and correspond to Scanivalves one through five.

A Scanivalve port address is represented by seven bits. The output of each multiplexer IC represents one of these bits. Multiplexer inputs are the corresponding bits from each of five Scanivalves.

Scanivalves physically define port addresses by grounding "true" bits; "false" bits are open circuit. Buffers U17-U22 invert address data bits to make multiplexer input logic conform to the "high" = "true" convention. Thus, grounded inputs to the buffers are output "high" while open inputs result in a "low" output [3].

#### 5. HANDSHAKE Section

The HANDSHAKE circuit is shown in Figure 13. This section executes the transfer of each information byte by manipulating the transfer lines. Circuit response is dependent upon the designated function of the S/V MUX PCB; i.e., as

LISTENER, TALKER or dormant. The driver circuits in bus transceiver U3 were permanently enabled. Therefore, line driver - enabling logic was incorporated into the individual driver inputs. Unused control lines REN, SRQ and EOI are shown with their required terminal resistor divider networks.

The circuit responds as a LISTENER whenever designated as a LISTENER ( $ADR_L$ ) or when the bus is in the COMMAND mode (ATN). As a LISTENER, the DAV line is received and the NRFD and NDAC lines are driven. Figure 14 shows the timing sequence of these transfer lines during the transfer of one byte from the computer. The received DAV line is sampled every 100-nsecs by the clocked flip-flop U7(a). Depending on the synchronization of the DAV signal with the clock signal, a time delay of approximately zero to 100-nsec will occur between time of receipt and the time DAV is available to the remainder of the circuit. The driven transfer lines are defined by the following expressions:

$$NRFD = DAV \cdot (LSN RDY)$$

$$NDAC = \overline{NRFD} \cdot (LSN RDY)$$

where  $(LSN RDY) = (ATN + ADR_L) \cdot \overline{IFC}$

The LSN RDY line is implemented by U29(a) and U29(b), the NRFD line by U28(c) and the NDAC line by U5, U31(c) and U31(d). (U31 was used to create an AND gate from available logic components.)

The circuit responds as a TALKER when so designated by the computer ( $ADR_T$ ). As a TALKER the DAV line is driven and the NRFD and NDAC lines are received. Figure 15 shows the timing



sequence of the transfer lines during the transfer of one data byte to the computer. Information is placed on the data lines whenever the DRIVE ENABLE line is true:

$$\text{DRIVE ENABLE} = (\overline{\text{ATN}} \downarrow \text{ADR}_T \downarrow \overline{\text{NRFD}})$$

Whenever this condition exists, Scanivalve address information is unconditionally present on the data lines. An end-of-record (EOR) signal is not provided by this circuit; therefore, the computer must be programmed not to expect or to require one. The driven DAV line is defined as:

$$\text{DAV} = (\text{DAV ENABLE}) \cdot \overline{\text{NRFD}}_{\text{DELAYED}} \cdot (\text{NDAC} \downarrow \overline{\text{CLEAR}})$$

When using open-collector bus drivers, a 2  $\mu\text{sec}$  delay is required to allow line ringing and signal transients to decay [2]. The delay was provided by U24, a retriggerable one-shot multivibrator, and U23, a positive-edge-triggered flip-flop. These components provide a pre-set delay between receipt of  $\overline{\text{NRFD}}$  and driving the DAV line "true". Figure 16 describes the time delay sequence. Adjustment of the time delay circuit is described in Section III-E.

#### 6. CLOCK and CLEAR Sections

The CLOCK and CLEAR circuit diagrams are shown in Figure 17. The CLOCK consists of multivibrator U8 and crystal Y1. The CLOCK output is a 10MHz sinusoidal signal and is available to the circuit sections shown in Figure 6.

The CLEAR section sets the initial operating state of the circuit when power is first applied and also monitors the IFC control line. Whenever the IFC or the PRE-CLEAR lines are "true", the following circuit state is set:

ADR<sub>L</sub> set false

ADR<sub>T</sub> set false

All HANDSHAKE driver lines disabled

DRIVE ENABLE set false

The pre-clear circuit provides an 8-msec "high" pulse to U29(c). When power is first applied, capacitor C2 charges through resistor R5. This develops a voltage which biases transistor Q1 into saturation and lowers the collector to nearly ground potential. The collector state is inverted by U5 to create the PRE-CLEAR pulse. When C2 is charged, no current flows through R5 and Q1 is cut-off. The collector potential then is at the supply voltage, and the inverted PRE-CLEAR signal is set "false". After the pre-clear sequence is complete, the CLEAR lines respond only to IFC.

#### 7. HP-IB Display

It is useful to the programmer to monitor circuit response to computer-issued commands. The HP-IB display circuit was added to provide front panel display of the ADR<sub>L</sub>, ADR<sub>T</sub> and stored data lines A1, A2, A3. The circuit is shown in Figure 18. The selected lines were input to open-collector inverters. When input lines are "true", the inverters sink enough current to allow the LED's to illuminate. When input lines are "false",

the inverter output becomes electrically transparent and the LED's do not illuminate.

#### D. HARDWARE DESCRIPTION

The S/V MUX PCB, shown in Figure 19, was laid out, photo etched and fabricated at the Naval Postgraduate School. Appendix C contains a complete description of components and wiring specifications.

#### E. "DAV" DRIVER LINE DELAY ADJUSTMENT

The DAV driver circuit was discussed in Section III (C5) and is shown in Figure 13. Adjustment of the 2  $\mu$ sec delay is easily accomplished using the HP-9830A computer and a single-trace memory oscilloscope. The oscilloscope is connected to the circuit as follows:

CONNECTIONS:	External Trigger to TP7
	Signal Input to TP8
SETTINGS:	Time Sweep: 1 $\mu$ sec/div
	Sweep: Single
	Max persistence
	Write mode
Trigger:	Ext (-) slope
	DC input
Signal:	1 volt/div
	DC (+) input

The HP-9830A is programmed, as follows, to perform successive read operations:

10 CMD "?G\$"	50 NEXT I
20 FOR I = 1 to 75	60 OUTPUT (13,70) 256,95;
30 A = RBYTE13	70 FORMAT 2B
40 WAIT 750	80 END

Execution of this program causes the DAV drive circuit to be active. Program line 40 provides 0.75 seconds to manually reset the oscilloscope sweep trigger. Many traces are required to "burn" a visible presentation onto the screen.

A negative-going signal on TP7 triggers U24 and the oscilloscope sweep. U24 output is driven low for the time interval determined by C4 and R6, then resets high. The low-high transition clocks the DAV ENABLE (high) state on U23 to the DAV bus driver U3 (TP8). Resistor R6 is adjusted until the oscilloscope presentation (from TP8) goes high 2  $\mu$ sec after receipt of the trigger pulse (from TP7).



#### IV. PROGRAMMING INSTRUCTIONS

##### A. I/O SPECIFICATIONS

The S/V MUX PCB was designed to receive one binary data byte and to transmit one binary data byte only. End of record codes (EOI, CR, LF) are neither transmitted nor processed by the PCB. When designated as a LISTENER, the PCB stores every byte sent to it by the bus CONTROLLER. For this reason, the CONTROLLER must be programmed to suppress terminal carriage return (CR) and line feed (LF) characters when communicating with the S/V MUX PCB. When designated as a TALKER the PCB can place only one information byte on the data lines and will transmit this byte repeatedly when requested by the CONTROLLER. For this reason, the CONTROLLER must be programmed to read data without requiring any end-of-record indication from the PCB.

The data byte received from the S/V MUX PCB is in the binary form shown in Figure 1. The bus CONTROLLER must decode this information.

##### B. SAMPLE PROGRAM CODE

References 4-8 contain programming specifications for the HP-9830A and HP-21MX computers. Tables A3 and A4 contain example program codes used to acquire steady-state data. The code used to communicate with the S/V MUX PCB is annotated and listed in the program lines as follows:

CONTROLLER

HP-9830A

HP-21MX

TABLE

A3

A4

PROGRAM LINES

295 - 360

INTEGER FUNCTION  
IPOINT

## V. CONCLUSIONS AND RECOMMENDATIONS

The HG-78K Scanivalve Controller described here, when used together with a Scanner and DVM, allows data acquisition from up to five Scanivalves on-line to any computer which is compatible with the Hewlett-Packard Interface Bus. Programs were developed and the operation of the controller was verified using both the HP-9830A and HP-21MX computers. Concurrent manual and computer-controlled operation of each Scanivalve without interference was provided for in the design.

The S/V MUX PCB in the controller was developed as a computer-peripheral device on the HP-IB to enable the computer to obtain Scanivalve address information. The logic circuitry developed and described here satisfied all functional requirements at low cost and high reliability.

While no changes in the design are necessary, a possible improvement in the MULTIPLEXER section is shown in Figure 20. The design in Figure 20 would provide greater input flexibility and fewer components than the initial design shown in Figure 12.

Table I  
Logical Equivalences















Table II  
Logic Circuit Conventions

- |    |  |   |
|----|--|---|
| 1. |               | Denotes edge connector  |
| 2. |               | Denotes chassis ground  |
| 3. |               | Denotes positive edge trigger.<br>(Information on inputs will transfer to the outputs when trigger line state transitions from low to high.)  |
| 4. | <p>"TRUE" = "HIGH" level = +2.4 to +5.0 Vdc</p> <p>"FALSE" = "LOW" level = 0.0 to +0.4 Vdc</p> |   |
| 5. |             | Denotes component U6, section (b). Input "x" comes from an edge connector; input "y" comes from another part of the circuit; variable "z" is routed to other circuit sections not shown on the diagram. |
| 6. |             | Denotes component U4 has an open-collector output.  |
| 7. |             | Line identifiers denote the mnemonic logic "high" state. The example shown represents a line that will be "high" when logic dictates a $\overline{DAV}$ (not DAV) condition.                            |

PNEUMATIC  
INPUT PORTS



6 5 4 3 2 1 0 - Bit Identification

10's BCD 1's BCD - Port Address Form

0 1 1 0 1 0 1 - Sample Binary Code

35 - Decimal Port Address

Figure 1

Scanivalve Functions




Figure 2: HG-78K Scanivalve Controller




Figure 3: Scanivalve-Computer System Installation






Figure 4: HG-78K Functional Block Diagram




Figure 5  
HP-IB Lines




Figure 6  
S/V MUX PCB Block Diagram




Figure 7  
Bi-Directional Bus Connections








Figure 8: Data I/O Section





# EXAMPLE

Word: 0100101 (ASCII %)

Meaning: Device with address decimal 5 to LISTEN

Figure 10  
HP-IB Address Word Format




Figure 11  
Data Storage Section







Figure 12  
Multiplexer Section




## Handshake Section



- $t_0$  Device designated a LISTENER.
- $t_1$  Information placed on data lines.
- $t_2$  TALKER indicates data is valid.
- $t_3$  Device indicates data is accepted and that it is not ready for more data.
- $t_4$  TALKER indicates data is invalid and removes information on data lines.
- $t_5$  Device return to state  $t_0$ .
- $\Delta$  Variable, 0-100 nano-sec.


Figure 14  
Listener Timing Diagram



- $t_0$  Device designated a TALKER; computer returns bus to data mode.
- $t_1$  Computer ready for data. Valid data on lines.
- $t_2$  Device indicates data is valid.
- $t_3$  Computer indicates receipt of data.
- $t_4$  Return to state  $t_1$ .
- $\Delta$  2  $\mu\text{sec}$

Figure 15  
Talker Timing Diagram





- $t_0$  U31(b) and U32(a) enabled.
- $t_1$   $\overline{\text{NRFD}}$  received; U24 triggered.
- $t_2$  Positive-edged clock pulse latches DAV enable state to DAV driver line.
- $t_3$   $\overline{\text{NDAC}}$  received; U23 (DAV) cleared; trigger reset by receipt of  $\overline{\text{NRFD}}$ .
- $\Delta_1$  2  $\mu\text{sec}$  delay; adjustable by resistor R6.
- $\Delta_2$  7.2  $\mu\text{sec}$  for HP-9830A.

Figure 16  
DAV Time Delay Sequence



Figure 17




Figure 18  
HP-IB Display




Figure 19: S/V MUX PCB





## APPENDIX A

### DATA ACQUISITION PROGRAM EXAMPLES

This section contains two programs which illustrate the code required to acquire steady-state data using the HP-9830A and HP-21MX computers. The programs were written in modular form to illustrate separately the codes used for each task. Except for INTEGER FUNCTION IPORT, programming efficiency was not intended. In both programs, HP-IB device codes were obtained from Table A1 and Scanner channel assignments were obtained from Table A2.

Table A1  
HP-IB Device Codes

<u>Device</u>	<u>21-MX LU#</u>	<u>9830</u>	
		<u>Talk</u>	<u>Listen</u>
21-MX HPIB PCB	7	@	[SP]
Scanner #1	8		!
DVM	10	C	#
HP-9830	11	D	\$
S/V MUX PCB	14	G	'

Table A2  
Scanner #1 Channel Assignments

S/V #	FUNCTION		
	Advance	Home	Read
1	00	05	10
2	01	06	11
3	02	07	12
4	03	08	13
5	04	09	14
I	I-1	I+4	I+9

#### APPENDIX A.1: HP-9830A BASIC Program

The program shown in Table A2 was written as a mainline program that calls task subroutines. Each subroutine completes one of three tasks; address interrogation, position control or transducer measurement. The program is straight forward and steps are annotated for clarity.

#### APPENDIX A.2: HP-21MX FORTRAN Program

The program shown in Table A4 was written as a mainline program with calls to subroutines which communicate with particular HP-IB peripheral devices.

Integer Function IPORT communicates with the S/V MUX PCB using RTE-IV system EXEC calls [5]. Single byte EXEC read and write commands operate on the upper half of the 16-bit word [2]. The factor 256 in lines 76 and 78 represents a shift left or right of 8-bits in the word used to transmit and receive data from the S/V MUX PCB.

Subroutine CNTL communicates with Scanner #1. As discussed in Reference 9, two ASCII characters are required to identify a Scanner channel. For channels ten or above, subroutine CODE can create the necessary ASCII string. For channels 00-09, however, leading zeros are ignored by CODE and the required ASCII string is not formed. To preserve leading zeros, direct ASCII conversion was achieved by adding octal 60 to both the upper and lower bytes of the 16-bit integer word ICHAN (line #124). In either case, the converted integer word is output to Scanner #1 as a two-byte ASCII string in A2 format.



Table A3

HP-9830A Program Listing

```

100 REM      BUS CONTROLLER:  HP-9830A
105 REM
110 REM      VARIABLES:
115 REM
120 REM      I = DESIRED S/V (1-5)
125 REM      A = PRESENT PORT ADDRESS
130 REM      P = DESIRED PORT ADDRESS
135 REM      C = SCANNER CHANNEL
140 REM      V = VOLTAGE
145 REM      Z = S/V DOUBLE BCD PORT CODE
150 REM      T = TEN'S DIGIT
155 REM      U = ONE'S DIGIT
160 REM      J = DUMMY VARIABLE
165 REM
170 REM      * * * MAINLINE * * *
175 REM
180 DIM B$(12)
185 DISP "ENTER S/V IDENT":
190 INPUT I
195 DISP "ENTER DESIRED PORT":
200 INPUT P
205 REM  DEFINE DVM FUNCTION CODES
210 B$="F1R2M3H1T3A1"
215 N2=2
220 IF I=2 OR I=3 THEN 230
225 N2=1
230 REM
235 REM  INTERROGATE S/V "I"
240 GOSUB 295
245 REM
250 REM  POSITION S/V "I" TO PORT "P"
255 GOSUB 370
260 REM
265 REM  READ AND PRINT PRESSURE
270 GOSUB 530
275 STOP
280 GOTO 185
285 REM -----
290 REM
295 REM      * * * INTERROGATION SUBROUTINE * * *
300 REM
305 CMD "CB"
310 OUTPUT (10,310)I:
315 FORMAT 0
320 CMD "CC"
325 Z=ABYTE(3)
330 U=BIAND(Z,15)
335 P=POT(Z,4)
340 T=BIAND(P,7)
345 A=10+I+U
350 OUTPUT (10,305,255,95)
355 FORMAT 24
360 RETURN

```

← "73" MUST BE SPECIFIED  
[REF. 10]

SEND 1 DATA BYTE TO MUX  
PCB (SUPPRESS CR/LF) [REF. 4]  
READ 1 DATA BYTE  
DECODE S/V ADDRESS  
UNTALK S/V MUX PCB

THIS PAGE IS BEST QUALITY PRACTICABLE  
FROM COPY FURNISHED TO DDC

```

365 REM
370 REM
375 REM
380 FORMAT F3.0
385 D=P-A
390 IF D=0 THEN 515
395 CMD "20!"
400 IF D>0 THEN 450
405 REM
410 REM HOME S/V "I"
415 REM
420 C=I+4
425 OUTPUT (13,380)C
430 OUTPUT (13,*)"C"
435 WAIT 4000
440 GOTO 495
445 REM
450 REM ADVANCE S/V "I" TO PORT "P"
455 REM
460 C=I-1
465 FOR J=1 TO D STEP N2
470 OUTPUT (13,380)C
475 OUTPUT (13,*)"C"
480 WAIT 50
485 NEXT J
490 REM
495 REM VERIFY ADDRESS & RETURN
500 REM
505 GOSUB 295
510 GOTO 385
515 RETURN
520 REM -----
525 REM
530 REM
535 REM
540 FORMAT B
545 FORMAT 38
550 FORMAT F3.0
555 CMD "20!"
560 C=I+9
565 OUTPUT (13,550)C
570 CMD "20"
575 OUTPUT (13,540)768
580 CMD "20#".8#
585 OUTPUT (13,540)256.8.512#
590 CMD "20#"
595 ENTER (13,*)V
600 WRITE (15,605)I,A,V
605 FORMAT "S/V",F2.0," PORT",F3.0," = ",F9.6," PSI"
610 CMD "20!", "C"
615 RETURN
620 END

```

\* \* \* CONTROL SUBROUTINE \* \* \*

- SCANNER TO LISTEN

- "HOME" CODE (TABLE A2)  
} CLOSE, OPEN RELAY AND  
PAUSE 4-SEC

- "ADVANCE" CODE (TABLE A2)

- ALLOW S/V MECHANISM TO  
RESET

\* \* \* MEASUREMENT SUBROUTINE \* \* \*

} CLOSE "READ" RELAY  
(TABLE A2)

- REMOTE ENABLE BUS  
- PROGRAM DVM FUNCTIONS  
- TRIGGER DVM  
} READ VOLTAGE

- CLEAR SCANNER

Table A4

HP-21MX Program Listing

```

0001  FTN4,L
0002      PROGRAM HG78K
0003  C
0004  C      BUS CONTROLLER: HP-21MX
0005  C
0006  C      VARIABLES:
0007  C
0008  C      IVALUE = DESIRED S/V (1-5)
0009  C      IAPR   = PRESENT PORT NUMBER
0010  C      IADES  = DESIRED PORT NUMBER
0011  C      ICHAN  = SCANNER CHANNEL
0012  C      VOLTS  = DVM VOLTAGE READING
0013  C
0014  C      * * * * * MAINLINE * * * * *
0015  C
0016  C      DATA ISTEP /1/
0017  C      WRITE(1,60)
0018  C      READ (1,50) IVALUE
0019  C      WRITE(1,62)
0020  C      READ (1,52) IADES
0021  C      IF (IVALUE.EQ.2 .OR. IVALUE.EQ.3) ISTEP=2
0022  C      10  IAPR = IPORT(IVALUE)
0023  C      IDEL = IADES - IAPR
0024  C      IF (IDEL) 100,300,200
0025  C
0026  C      HOME SCANIVALVE
0027  C
0028  C      100  ICHAN = IVALUE + 4
0029  C      CALL CNTL(ICCHAN,2)
0030  C      GO TO 10
0031  C
0032  C      ADVANCE SCANIVALVE
0033  C
0034  C      200  ICHAN = IVALUE - 1
0035  C      DO 210 J=1,IDEL,ISTEP
0036  C      210  CALL CNTL(ICCHAN,1)
0037  C      GO TO 10
0038  C
0039  C      MEASURE TRANSDUCER
0040  C
0041  C      300  ICHAN = IVALUE + 9
0042  C      CALL CNTL(ICCHAN,3)
0043  C      CALL DVM(VOLTS)
0044  C
0045  C      LIST STEADY-STATE DATA
0046  C
0047  C      WRITE(1,64) IVALUE, IAPR, VOLTS
0048  C      WRITE(8,66)
0049  C      STOP
0050  C
0051  C      50  FORMAT(I1)
0052  C      52  FORMAT(I2)
0053  C      60  FORMAT("S/V #1:")
0054  C      62  FORMAT("DESIRED PORT #1:")
0055  C      64  FORMAT("S/V    PORT    VOLTS"/1X,I1,6X,I2,3X,F9.6)
0056  C      66  FORMAT("C")
0057  C      END

```

FTN4 COMPILER: HP92060-16092 REV. 1805 (780310)

\*\* NO WARNINGS \*\* NO ERRORS \*\* PROGRAM = 00176 COMMON = 00000

THIS PAGE IS BEST QUALITY PRACTICABLE  
FROM COPY FURNISHED TO DDC

```
0058      INTEGER FUNCTION IPORT (IVALVE)
0059 C
0060 C      THIS PROGRAM INTERROGATES SCANIVALVE
0061 C      "IVALVE" AND CONVERTS PORT ADDRESS
0062 C      INTO A DECIMAL VALUE.
0063 C
0064 C      S/V MUX PCB = LU#14
0065 C      HPIB BUS PCA = LU#7
0066 C
0067 C      VARIABLES:
0068 C
0069 C      IVALVE = DESIRED S/V
0070 C      IP      = S/V INPUT BUFFER
0071 C      MSD     = MOST SIGNIF. DIGIT
0072 C      LSD     = LEAST SIGNIF. DIGIT
0073 C      IPORT  = DECIMAL S/V ADDRESS
0074 C
0075      LU = 14 + 21008      — CONFIGURE DRIVER WORD
0076      CALL EXEC(2,LU,IVALVE*256,-1)      [REF 5 P.3-3]
0077      CALL EXEC(1,LU,IP,-1)
0078      IP=IP/256
0079      MSD = IAND(IP/16,7B)
0080      LSD = IAND(IP,17B)
0081      IPORT = 10*MSD + LSD
0082      CALL ABRT(7,1)
0083      RETURN
0084      END
```

FTN4 COMPILER: HP92060-16092 REV. 1805 (780310)

\*\* NO WARNINGS \*\* NO ERRORS \*\* PROGRAM = 00068 COMMON = 00000



```

0085      SUBROUTINE CNTL (ICHAN,K)
0086      C
0087      C      THIS PROGRAM CONTROLS THE
0088      C      CLOSING OF SCANNER RELAYS.
0089      C      PROGRAM OPTIONS ARE INPUT
0090      C      THROUGH VARIABLE "K" AS:
0091      C
0092      C      K      FUNCTION
0093      C      -----
0094      C      1      CLOSE RELAY FOR 10-MS,
0095      C      OPEN RELAY, RETURN
0096      C
0097      C      2      SAME AS K=1 EXCEPT
0098      C      DELAY 4-SEC PRIOR TO RTN.
0099      C
0100      C      3      CLOSE RELAY, RETURN.
0101      C      -----
0102      C
0103      C      SCANNER LU#=8
0104      C
0105      C      VARIABLES:
0106      C
0107      C      ICHAN = SCANNER CHANNEL
0108      C      J      = ASCII STRING
0109      C
0110      C      IF(ICHAN.LT.0 .OR. ICHAN.GT.14) GO TO 900
0111      C      IF(ICHAN.LT.10) GO TO 100
0112      C
0113      C      ASCII CONVERSION
0114      C      ICHAN >= 10
0115      C
0116      C      CALL CODE
0117      C      WRITE(J,60) ICHAN
0118      C      60  FORMAT(I2)
0119      C      GO TO 200
0120      C
0121      C      ASCII CONVERSION
0122      C      ICHAN < 10
0123      C
0124      C      100  J = ICHAN + 30060B      - ADD 608 TO UPPER & LOWER BYTES
0125      C
0126      C      CLOSE RELAY
0127      C
0128      C      200  WRITE(8,65)J          } SEND INTEGER "J" AS
0129      C      65  FORMAT(A2)          } 2-BYTE ASCII STRING
0130      C      IF(K .EQ. 3) RETURN
0131      C
0132      C      10-MS TIME DELAY
0133      C
0134      C      CALL WAIT(1)
0135      C
0136      C      OPEN RELAY
0137      C
0138      C      WRITE(8,68)
0139      C      68  FORMAT("C")
0140      C
0141      C      150-MS TIME DELAY
0142      C
0143      C      CALL WAIT(15)
0144      C      IF(K .EQ. 1) RETURN
0145      C
0146      C      4-SEC TIME DELAY
0147      C
0148      C      CALL WAIT(400)
0149      C      RETURN
0150      C      900  WRITE(1,90) ICHAN
0151      C      90  FORMAT("ILLEGAL SCANNER CHAN INPUT TO SUBR CNTL: ",I4)
0152      C      RETURN
0153      C      END

```

FTN4 COMPILER: HP92060-16092 REV. 1805 (780310)

\*\* NO WARNINGS \*\* NO ERRORS \*\* PROGRAM = 00127 COMMON = 00000

THIS PAGE IS BEST QUALITY PRACTICABLE  
FROM COPY FURNISHED TO DDC

```
0154      SUBROUTINE DVM (VOLTS)
0155 C
0156 C          THIS PROGRAM CONTROLS
0157 C          THE HP-3455A DVM.
0158 C
0159 C          DVM LU#=10
0160 C          HP1B LU#=7
0161 C
0162 C          CALL RMOTE (10)
0163 C          CALL CLEAR (10,1)
0164 C          WRITE (10,60)
0165 C          CALL TRIGR (10)
0166 C          READ (10,*) VOLTS
0167 C          RETURN
0168 60      FORMAT ("F1R2M3A0T3")
0169      END
```

FTN4 COMPILER: HP92060-16092 REV. 1805 (780310)

\*\* NO WARNINGS \*\* NO ERRORS \*\* PROGRAM = 00039 COMMON = 00000

```
0170      SUBROUTINE WAIT (N)
0171 C
0172 C          THIS PROGRAM USES THE HP-21MX
0173 C          SYSTEM CLOCK TO PRODUCE A
0174 C          DELAY OF (N*10)-MILLISECONDS.
0175 C
0176 C          VARIABLES:
0177 C
0178 C          NM = # OF MINUTES
0179 C          IT = INPUT TIME BUFFER
0180 C          ITF = COMPUTED FINAL TIME
0181 C          INOW = PRESENT TIME
0182 C
0183 C
0184 C          DIMENSION IT(5)
0185 C          CALL EXEC (11,IT,IY)
0186 C          NM=IT(3)
0187 C          ITF=IT(1) + 100*IT(2) + N
0188 10      IF(ITF.LE.5999) GO TO 20
0189 C          NM=NM + 1
0190 C          ITF=ITF - 6000
0191 C          GO TO 10
0192 20      CALL EXEC (11,IT,IY)
0193 C          INOW=IT(1) + 100*IT(2)
0194 C          IF(ITF-INOW)30,30,20
0195 30      IF(NM-IT(3))99,99,20
0196 99      RETURN
0197      END
```

FTN4 COMPILER: HP92060-16092 REV. 1805 (780310)

\*\* NO WARNINGS \*\* NO ERRORS \*\* PROGRAM = 00092 COMMON = 00000

APPENDIX B  
HG-78K HARDWARE

APPENDIX B.1: HG-78K Input/Output Wiring

This section documents the I/O wiring of the HG-78K Scanivalve Controller. Figure B1 shows the back panel layout and Tables B1 through B6 list the associated wiring connections. Figure B2 shows the Scanivalve transducer signal conditioning circuit with associated back and front panel connections.

APPENDIX B.2: S/V Address Decoder/Display PCB

The address lines in a Scanivalve are connected to circuit ground to define a "true" state. In the DECODER/DISPLAY, the address lines were connected to 7404 inverters in order to convert to the "high" = "true" logic required for input to HP-5082 -7300 BCD-DECIMAL decoder/driver display integrated circuits. The circuit is shown in Figure B3 and external wiring is listed in Table B7.




Figure B1  
HG-78K Back Panel Layout



Table B1  
24-Pin HP-IB Connector

HP-IB PIN #	FUNCTION	S/V MUX PCB LEFT EDGE CONNECTOR
1	DI01	19
2	DI02	20
3	DI03	22
4	DI04	21
5	EOI	N
6	DAV	2
7	NRFD	4
8	NDAC	3
9	IFC	1
10	SRQ	L
11	ATN	8
12	NC	
13	DI05	5
14	DI06	6
15	DI07	10
16	DI08	17
17	REN	R
18	CKT GND	J
19	CKT GND	J
20	CKT GND	J
21	CKT GND	J
22	CKT GND	J
23	CKT GND	J
24	CKT GND	J

Table B2  
19-Pin Transducer Connector

PIN	FUNCTION	WIRE
A	TX #1; Pin B	White
B	TX #1; Pin C	Green
C	Shield #1	Black
D	TX #2; Pin B	White
E	TX #2; Pin C	Green
F	Shield #2	Black
G	TX #3; Pin B	White
H	TX #3; Pin C	Green
J	Shield #3	Black
K	TX #4; Pin B	White
L	TX #4; Pin C	Green
M	Shield #4	Black
N	TX #5; Pin B	White
P	TX #5; Pin C	Green
R	Shield #5	Black
S	NC	
T	NC	
U	NC	
V	NC	

Table B3  
14-Pin Frequency Connector

PIN	FUNCTION	WIRE
A	BNC #1	OR
B	GND	BL
C	BNC #2	OR
D	GND	BL
E	BNC #3	OR
F	GND	BL
G	BNC #4	OR
H	GND	BL
I	BNC #5	OR
J	GND	BL

Table B4  
19-Pin Scanivalve Input Connectors

PIN	S/V Connector #					FUNCTION
	1	2	3	4	5	
A						Chassis ground
B						Logic ground
C						+24 VDC
D						Advance
E						Home
F	1/0	2/0	3/0	4/0	5/0	Address bit 0
G	1/1	2/1	3/1	4/1	5/1	Address bit 1
H	1/2	2/2	3/2	4/2	5/2	Address bit 2
J	1/3	2/3	3/3	4/3	5/3	Address bit 3
K	1/4	2/4	3/4	4/4	5/4	Address bit 4
L	1/5	2/5	3/5	4/5	5/5	Address bit 5
M	1/6	2/6	3/6	4/6	5/6	Address bit 6
N						Address common (ground)



Table B5  
6-Pin Scanivalve Advance Connector


SOURCE *	PIN	SCANNER CHANNEL
Pin B	A	
S/V #1; Pin D	B	00
S/V #2; Pin D	C	01
S/V #3; Pin D	D	02
S/V #4; Pin D	E	03
S/V #5; Pin D	F	04

Table B6  
6-Pin Scanivalve Home Connector

SOURCE *	PIN	SCANNER CHANNEL
Pin B	A	
S/V #1; Pin E	B	05
S/V #2; Pin E	C	06
S/V #3; Pin E	D	07
S/V #4; Pin E	E	08
S/V #5; Pin E	F	09

\*Table B4





IC	INPUT	PIN CONNECTIONS	COMPONENT TYPE
D1-D5	+5 GND	4, 8, 11, 15 9, 10, 13, 14	NUMERIC DISPLAY HP-5082-7300 (2 ea./socket)
U1-U7	+5 GND	14 7	7404 HEX INVERTER

Figure B3: Scanivalve Address Decoder/Display Circuit

Table B7

## S/V Address Decoder/Display Edge Connections

<u>Component Side</u>			<u>Foil Side</u>	
	Ground	1 - A	1/4	Wht
Red	1/5	2 - B	1/6	Red
		3 - C	1/1	Blk
Blk	1/2	4 - D	1/3	Grn
Wht	1/0	5 - E	2/4	Grn
Red	2/5	6 - F	2/6	Wht
		7 - H	2/1	Grn
Wht	2/2	8 - J	2/3	Blk
Grn	2/0	9 - K	3/4	Grn
Blk	3/5	10 - L	3/6	Blk
		11 - M	3/1	Red
Grn	3/2	12 - N	3/3	Red
Grn	3/0	13 - P	4/4	Red
		14 - R	4/5	Grn
		15 - S	4/6	Grn
		16 - T	4/1	Wht
Red	4/2	17 - U	4/3	Blk
Red	4/0	18 - V	5/4	Blk
Wht	5/5	19 - W	5/6	Wht
		20 - X	5/1	Blk
Wht	5/2	21 - Y	5/3	Wht
		22 - Z	5/0	Red
	+5Vdc			

EXAMPLE

PIN F is Scanivalve #2, bit 6 and has a white wire connected to its terminal.



## APPENDIX C

### S/V MUX PCB HARDWARE

A component listing is given in Table C1. Test points provided on the circuit board are summarized in Table C2. External connections are given in Tables C3 and C4.

Table C1

## S/V MUX PCB Component Listing

Integrated Circuits

U1	MC3441P
U2	MC3441P
U3	MC3441P
U4	7404
U5	7404
U6	9324DC
U7	74LS175
U8	MC4024P
U9	74LS175
U10	74LS151
U11	74LS151
U12	74LS151
U13	74LS151
U14	74LS151
U15	74LS151
U16	74LS151
U17	7404
U18	7404
U19	7404
U20	7404
U21	7404
U22	7404
U23	7474
U24	74LS122
U25	7430
U26	7430
U27	7420
U28	7408

U29	7402
U30	7400
U31	7400
U32	7408

Resistors

R1	3.0K
R2	6.2K
R3	4.7K
R4	4.7K
R5	4.7K
R6	50K (10-turn)
R7	3.0K
R8	6.2K
R9	3.0K
R10	6.2K
R11	3.0K
R12	6.2K

Capacitors

C1	10 $\mu$ F TANTALUM
C2	5 $\mu$ F ELECTROLYTIC
C3	.1 $\mu$ F
C4	360pF

Transistor

Q1	2N3904
----	--------

Crystal

Y1	56MHZ
----	-------

Table C2

S/V MUX PCB Test Point Summary

TP1	Clock
TP2	Data Store
TP3	ADR <sub>L</sub>
TP4	ADR <sub>T</sub>
TP5	DAV Enable
TP6	Clear
TP7	Trigger
TP8	DAV Driver

Table C3  
S/V MUX PCB Left Edge Connections

<u>Left Edge Connector</u>						
↓						
<u>Component Side</u>			<u>Foil Side</u>			
			A - 1	IFC	(BLK)	9
			B - 2	DAV	(WHT)	6
			C - 3	NDAC	(GRN)	8
			D - 4	NRFD	(RED)	7
			E - 5	DI05	(BLK)	13
Pwr supp	(RED)	+5Vdc	F - 6	DI06	(WHT)	14
			H - 7			
24	(BLK)	CKT GND	J - 8	ATN	(GRN)	11
			K - 9			
10	(WHT)	SRQ	L - 10	DI07	(RED)	15
			M - 11			
5	(RED)	EOI	N - 12			
			P - 13			
17	(GRN)	REN	R - 14			
			S - 15			
			T - 16			
Pwr supp	(BLK)	Supp GND	U - 17	DI08	(BLK)	16
			V - 18			
			W - 19	DI01	(WHT)	1
			X - 20	DI02	(GRN)	2
			Y - 21	DI04	(RED)	4
			Z - 22	DI03	(BLK)	3
↑			↑			
<u>HP-IB Connector</u>						

EXAMPLE: PIN 8 is the ATN line connected by a green wire from HP-IB connector PIN 11.



Table C4

S/V MUX PCB Right Edge Connections

<u>Right Edge Connector</u>						
			↓			
<u>Component Side</u>				<u>Foil Side</u>		
		Ground	A - 1	Ground		
			B - 2			
		+5 Vdc	C - 3	+5 Vdc		
G/2	(GRN)	2/1	D - 4			
G/3	(RED)	3/1	E - 5	5/3	(WHT)	J/5
G/5	(BLK)	5/1	F - 6	2/4	(GRN)	K/2
H/2	(WHT)	2/2	H - 7	4/4	(RED)	K/4
J/1	(GRN)	1/3	J - 8	4/3	(BLK)	J/3
J/3	(RED)	3/3	K - 9	1/4	(WHT)	K/1
H/1	(BLK)	1/2	L - 10	3/4	(GRN)	K/3
G/4	(WHT)	4/1	M - 11	1/5	(RED)	L/1
F/2	(GRN)	2/0	N - 12	3/5	(BLK)	L/3
F/4	(RED)	4/0	P - 13	5/5	(WHT)	L/5
G/1	(BLK)	1/1	R - 14	4/5	(GRN)	L/4
F/1	(WHT)	1/0	S - 15	2/5	(RED)	L/2
F/3	(GRN)	3/0	T - 16	5/4	(BLK)	K/5
F/5	(RED)	5/0	U - 17	2/6	(WHT)	M/2
J/2	(BLK)	2/3	V - 18	4/6	(GRN)	M/4
H/5	(WHT)	5/2	W - 19	1/6	(RED)	M/1
H/3	(GRN)	3/2	X - 20	3/6	(BLK)	M/3
H/4	(RED)	4/2	Y - 21	5/6	(WHT)	M/5
		Ground	Z - 22	Ground		

↑
↑

Scanivalve 19-Pin

### EXAMPLE

PIN 10 is S/V3, bit 4 connected by a green wire from PIN K of Scanivalve 19-Pin connector #3.

## LIST OF REFERENCES

1. Naval Postgraduate School Report 57Va72091A, A Description of the Turbopropulsion Laboratory in the Aeronautics Department at the Naval Postgraduate School, by M.H. Vavra and R.P. Shreeve, September 1972.
2. Operating and Service Manual, Bus Input/Output Interface Kit 59310A, Hewlett-Packard, 1975.
3. Lancaster, D., TTL Cookbook, Sams, 1976.
4. Operating Manual, 11272B Extended I/O ROM, Hewlett-Packard, 1972.
5. User's Guide, HP 59310A/B Interface Bus I/O Kit, Hewlett-Packard, 1977.
6. User's Manual, The HP-IB in HP 1000 Computer Systems, Hewlett-Packard, 1978.
7. User's Guide, Hewlett-Packard Interface Bus for Systems Based on the HP-9830A Calculator, Hewlett-Packard, 1974.
8. Programming and Service Manual, HP-IB Calculator Interface 59405A, Hewlett-Packard, 1974.
9. Programming and Service Manual, HP-3495A Scanner, Hewlett-Packard, 1977.
10. Operating Information, HP-3455A Digital Voltmeter, Hewlett-Packard, 1976.

# INITIAL DISTRIBUTION LIST

	No. Copies
1. Defense Documentation Center Cameron Station Alexandria VA 22314	2
2. Library, Code 0142 Naval Postgraduate School Monterey CA 93940	2
3. Department Chairman, Code 67 Department of Aeronautics Naval Postgraduate School Monterey CA 93940	1
4. Assoc. Professor R.P. Shreeve, Code 67Sf Department of Aeronautics Naval Postgraduate School Monterey CA 93940	1
5. LT R.N. Geopfarth, USN 2211 Cecelia Terrace San Diego CA 92110	1
6. Mr. J.E. Hammer, Code 67 Department of Aeronautics Naval Postgraduate School Monterey CA 93940	1
7. Mr. J.C. King, Code 67 Department of Aeronautics Naval Postgraduate School Monterey CA 93940	1
8. Turbopropulsion Laboratory, Code 67 Naval Postgraduate School Monterey CA 93940	10
9. Dr. H.J. Mueller Naval Air Systems Command, Code 310A Department of the Navy Washington DC 20361	1
10. Mr. Karl H. Guttman Naval Air Systems Command, Code 330C Department of the Navy Washington DC 20361	1

- |     |  |   |
|-----|--|---|
| 11. | Commanding Officer<br>ATTN: Mr. Al Martino<br>Naval Air Propulsion Center<br>Trenton NJ 08628                                  | 1 |
| 12. | Mr. James R. Patton, Jr.<br>Power Program, Code 473<br>Office of Naval Research<br>Arlington VA 22218                          | 1 |
| 13. | National Aeronautics and Space Administration<br>Lewis Research Center (Library)<br>21000 Brookpark Road<br>Cleveland OH 44135 | 1 |
| 14. | Library<br>General Electric Company<br>Aircraft Engine Technology Division<br>DTO Mail Drop H43<br>Cincinnati OH 45215         | 1 |
| 15. | Library<br>Pratt & Whitney Aircraft<br>Post Office Box 2691<br>West Palm Beach FL 33402  | 1 |
| 16. | Library<br>Pratt & Whitney Aircraft<br>East Hartford CT 06108  | 1 |
| 17. | Library<br>AiResearch Mfg. Corporation<br>Division of Garrett Corporation<br>402 South 36th Street<br>Phoenix AZ 85034         | 1 |
| 18. | Library<br>Detroit Diesel Allison<br>Division of General Motors Corporation<br>Indianapolis IN 46206                           | 1 |
| 19. | Library<br>CAG Boeing Company<br>Seattle WA 98124  | 1 |
| 20. | Library<br>Army Aviation Material Laboratories<br>Department of the Army<br>Fort Eustice VA 23604                              | 1 |




- |     |  |   |
|-----|--|---|
| 21. | Library<br>Air Force Aero Propulsion Laboratory (AFSC)<br>Wright Patterson Air Force Base OH 45433 | 1 |
| 22. | Library<br>The Pennsylvania State University<br>University Park PA 16802                           | 1 |
| 23. | Library<br>Iowa State University<br>Ames IA 50010  | 1 |
| 24. | Library<br>Massachusetts Institute of Technology<br>Cambridge MA 02139                             | 1 |

END

DATE  
FILMED

6-79



AD-A067 694

NAVAL POSTGRADUATE SCHOOL MONTEREY CALIF  
DEVELOPMENT OF A DEVICE FOR THE INCORPORATION OF MULTIPLE SCANI--ETC(U)  
MAR 79 R N GEOPFARTH

F/G 9/2

UNCLASSIFIED

NPS67-79-002

NL

2 OF 2  
AD A  
067694



SUPPLEMENTARY  
INFORMATION



END  
DATE  
FILMED  
4-81  
DTIC





**SUPPLEMENTARY**

**INFORMATION**

NAVAL POSTGRADUATE SCHOOL

MONTEREY, CALIFORNIA - 93940

IN REPLY REFER TO:

NC4(67Sf)/hkg  
9 January 1981

Department of Aeronautics

AD-A067694

Dear Sir,

Enclosed are revisions to the publication "Development of a Device for the Incorporation of Multiple Scani-valves into a Computer-Controlled Data System" by Robert Neldon Geopfarth, Naval Postgraduate School Technical Report NPS67-79-002 and M.S. Thesis, March 1979.

Revisions have been made to pages 26, 47, 49 and 50. The enclosed revised pages should be inserted in place of the original pages in your copy, or copies, of this document.

Sincerely,

*Raymond P. Shreeve*

Dr. R. P. Shreeve  
Director, Turbopropulsion  
Laboratory

sequence of the transfer lines during the transfer of one data byte to the computer. Information is placed on the data lines whenever the DRIVE ENABLE line is true:

$$\text{DRIVE ENABLE} = (\overline{\text{ATN}} \downarrow \text{ADR}_T \downarrow \overline{\text{NRFD}}); \text{ LATCHED BY U23(b)}$$

Once this condition exists, Scanivalve address information is unconditionally present on the data lines until cleared by receipt of  $\overline{\text{NDAC}}$ . An end-of-record (EOR) signal is not provided by this circuit; therefore, the computer must be programmed not to expect or to require one. The driven DAV line is defined as:

$$\text{DAV} = (\text{DAV ENABLE}) \cdot \overset{\text{U31(a)}}{\downarrow} \overline{\text{NRFD}}_{\text{DELAYED}} \cdot \overset{\text{U29(d)}}{\downarrow} (\text{NDAC} \cdot \overline{\text{CLEAR}})$$

When using open-collector bus drivers, a 2  $\mu\text{sec}$  delay is required to allow line ringing and signal transients to decay [2]. The delay was provided by U24, a retriggerable one-shot multi-vibrator, and U23(a), a positive-edge-triggered flip-flop. These components provide a pre-set delay between receipt of  $\overline{\text{NRFD}}$  and driving the DAV line "true". Figure 16 describes the time delay sequence. Adjustment of the time delay circuit is described in Section III-E.

## 6. CLOCK and CLEAR Sections

The CLOCK and CLEAR circuit diagrams are shown in Figure 17. The CLOCK consists of multi-vibrator U8 and crystal Y1. The CLOCK output is a 10MHz sinusoidal signal and is available to the circuit sections shown in Figure 6.








Figure 13  
Handshake Section



- $t_0$  Device designated a TALKER; computer returns bus to data mode.
- $t_1$  Computer ready for data. Valid data on lines.
- $t_2$  Device indicates data is valid.
- $t_{2a}$  Computer arbitrarily resets NRFD.
- $t_3$  Computer indicates receipt of data.
- $t_4$  Return to state  $t_1$ .
- $\Delta$  2  $\mu$ sec

Figure 15  
Talker Timing Diagram



- $t_0$  U31(b) and U32(a) enabled.
- $t_1$   $\overline{\text{NRFD}}$  received; U24 triggered, U23(b) Drive enable clocked latching logic true on output line.
- $t_2$  Positive-edged clock pulse latches DAV enable state to DAV driver line.
- $t_{2a}$  Trigger reset by receipt of NRFD.
- $t_3$   $\overline{\text{NDAC}}$  received; U23(a) (DAV) and U23(b) (Drive enable) cleared. Data is removed from bus lines.
- $\Delta_1$  2  $\mu\text{sec}$  delay; adjustable by resistor R6.
- $\Delta_2$  7.2  $\mu\text{sec}$  for HP-9830A.

Figure 16  
DAV Time Delay Sequence